



MATERIAL DESCRIPTION			
MODEL	KEY	QTY	HORIZONTAL FARM SERVICE SKID TANK
Tank Diameter			5'-4"
Tank Length			9'-0"
Capacity			1,500 US Gallons Nominal
Tank Gauge			10 Gauge
Code			None Code
Supports	A	2	Skids Full Length - 10 Gauge
Fill Opening	B	1	2" 150# Weld Flange W/Plastic Cap
Pump Opening	C	1	2" 150# Weld Flange W/Plastic Cap
Gauge Opening	D	1	2" 150# Weld Flange W/Plastic Cap
Op Vent Opening	E	1	2" 150# Weld Flange W/Plastic Cap
Remote Level Gauge	I	1	2" 150# Weld Flange W/Plastic Cap
Lift Lug	J	2	Small Lift Lug
Tank Drain	K	1	1" 150# Weld Flange
Mfg Label	L	1	CTM Label W/Lift Lug Warning Label

CUSTOMER APPROVAL NEEDED
BEFORE PRODUCTION

NAME _____

DATE _____

Surface Prep: Brush Blast
Paint: Polane White
Operating Pressure: Atmospheric
Estimated Dry Weight: 1,250 lbs

"Please enlist the services of a qualified/certified tank installer for any post manufacturing on-site pressure testing requirements. Over pressurization can cause tank deformation, mechanical failure and/or catastrophic failure of tank."

NOTICE

THIS DRAWING IS THE PROPERTY OF CERTIFIED TANK & EQUIPMENT CO. CERTIFIED TANK & EQUIPMENT CO. RESERVES ITS RIGHTS IN THIS DRAWING, ITS SUBJECT MATTER, AND THE DESIGN THEREIN DISCLOSED. THIS COPY IS LOANED SUBJECT TO THE AGREEMENT AND CONDITION THAT IT OR ITS SUBJECT MATTER IS NOT TO BE DISCLOSED IN WHOLE OR IN PART, TO ANY OTHER PARTY, AND THAT IT SHALL NOT BE COPIED IN ANY FORM WITHOUT EXPRESS WRITTEN PERMISSION OF CERTIFIED TANK & EQUIPMENT CO. ACCEPTANCE OF THIS COPY WILL BE CONSTRUED AS ACCEPTANCE OF THE FOREGOING CONDITION.

REVISIONS

REV A-4/23/13
REV B-8/25/15

64" x 108" 1,500 GAL. FARM SERVICE SKID TANK
CTM STANDARD 2" FILL W/DRAIN



CERTIFIED
TANK & MANUFACTURING, LLC

DRAWN BY JDH DATE 8/26/16

CHECKED BY DATE

SCALE

N/A

DRAWING NO.

1.5KHFSN64.108-01021CA

SCALE

