



Innovative Heating Solutions



GUARDIAN® & CLASSIC™

Forced Air Heater Maintenance

L.B. White Forced Air Heater Maintenance Checklist

The last thing you need to worry about it are your swine heaters. L.B. White Forced Air Heaters work flawlessly for years when they're regularly maintained. Taking necessary precautions saves money in the short- and long-run when it's absolutely necessary to squeeze profit out of every dollar. The following heater maintenance checklist will help keep your L.B. White forced air heaters working at peak performance during the cold winter months.

At Each Turn

1. Review all labels. If new data plates and labels are needed, contact L.B. White for replacements.
Email: customerservice@lbwhite.com
Call: 800-345-7200 (toll-free)
2. Check and replace any wires that are frayed, cut or corroded at the terminal.
3. Replace any cut or nicked gas hoses and corroded fittings.
4. Clean the heater with compressed air, a brush or a rag. (DO NOT use water when cleaning internal components.)
5. Remember to turn the manual gas valve up in the fall, down in the spring.

Once per Year

1. Check the regulator. Look for any blockages in the vents.
2. Check date codes (performed by gas supplier).
3. Inspect the gas piping and check for leaks (performed by gas supplier).
4. Clean sediment traps (performed by gas supplier).

