




DETAIL A




TOP VIEW



LEFT SIDE



FRONT VIEW



RIGHT SIDE

NOTES:

- A. Quantity:
- B. Material: H.R. Carbon Steel
- C. Inner Tank: 10 GA
- D. Outer Tank: 12 GA w/ 10 Ga. Common Top
- E. Design & Operating Pressure: Atmospheric.
- F. Design & Operating Temperature: Ambient.
- G. Tank to be Built & Labeled per U.L. Spec. #142.
- H. Tank to Bear Manufacturers & U.L. Labels Only.
- I. Tank to be Air Tested with Water & Soap Suds Solution.
- J. Interior: Remove Weld Slag (Ship Clean & Dry).
- K. Exterior: Gray primer included; see Sales Order for top coat.
- L. All Fittings to be Protected for Shipment.
- M. Customer has the Responsibility to Verify All Dimensions.

*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.

APPROVAL FOR CONSTRUCTION
SCHEDULE A - MASTER TERMS & CONDITIONS OF SALE*

APPROVED AS DRAWN.
 APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.
SIGNATURE _____
DATE: _____

SALES ORDER #

JME ELLSWORTH
A John M. Ellsworth Company

VESSEL DESCRIPTION:

750 GALLON RECTANGULAR UL 142 DOUBLE WALL TANK

CUSTOMER:

P.O. #

DATE:

SCALE:

DWG. # NEFTDBS0750
CHKD. BY: TB