



ELEVATION ANGLE  
FEET

REF. TO: STANDARD TANK

DATE: 05/20/08

DWG BY: AH

TITLE: **LVDW-275-12P**

SCALE: 1:16

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL  
12 GA. INNER/12 GA. OUTER  
STEEL STORAGE TANK

FINISH:

SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT: 550 lbs ± 5%

CAPACITY:

265 GALLONS



Underwriters  
Laboratories Inc.  
LISTED

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (4) 2" NPT CPL                      D - (1) 2" INSPECTION PIPE  
B - (1) 3" INNER E.VENT CPL        E - (1) LIFTING LUG  
C - (1) 3" OUTER E.VENT FLANGE

SIGNED APPROVAL: