

Ultra-Gutter Guard

Specification



1.1 This work shall consist of furnishing, installing, maintaining, and removing Ultra-Gutter Guard sediment control device as directed by the engineer or as shown on the site drawings.

2.0 Ultra-Gutter Guard Materials

2.1 GUTTER GUARD

The Gutter Guard shall be synthetic filter manufactured from recycled synthetic fibers.

2.1.1 The Gutter Guard will be manufactured to be 9" in diameter and are available in 8', 10', and 12' lengths and a minimum of twenty-four (24) inches longer than the curb inlet opening. This will allow for sufficient length to cover the inlet with twelve (12) inches beyond the inlet on both ends.

3.0 Construction Sequence

3.1 General

3.1.1 Install the Gutter Guard in front of the curb inlet opening. Each end of the Gutter Guard should overlap the curb inlet approximately 12".

3.1.2 The Gutter Guard should be cleaned if a visual inspection shows silt and debris build up around the Gutter Guard.

3.1.3 To remove the Gutter Guard, lift out of the opening.



John M. Ellsworth Co., Inc.

P.O. Box 240072
8700 West Bradley Road
Milwaukee, WI 53224

800-333-3331 **PHONE**

info@jmesales.com **E-MAIL**
www.JMESales.com **WEB**

3.0 Construction Sequence (continued)

3.1.4 The Gutter Guard is reusable. Once the construction project is complete and it is no longer needed for sediment control, remove, clean and store out of the sunlight until needed on the next project.

3.1.5 Ponding is likely if sediment is not removed regularly. Inspection of Gutter Guard should be on a regular basis and immediately after major rain events.