

| STP Description | responsible for infrastructure a optimizes fuel design makes service. Availal lengths. As a V | t Red Armor (RA) Submersible Turbine Pump driving fuel from the storage tank, through t and into the vehicle through the use of press flow and dispensing, and its advanced packe it the industry's easiest and safest STP to ins ble in 3/4 HP to 2 HP configurations in variab eeder-Root flagship product line, Red Jacket work of distributors and authorized service rldwide. | | | |
|-------------------------|---|--|--|--|--|
| | Part # | Description | Model # | Notes | |
| | 0410141-088 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 74.5" - 105" Length | AGP150S1 RA1 | 1.5 HP, 1.13 KW, 208/230 Voltage, single-phase. Length is in inches, measured from top of the eyebolt to the bottom of the motor inlet. | |
| | 0410141-089 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 104.5" - 165" Length | AGP150S1 RA2 | | |
| 4" Red Jacket RA STP | 0410141-090 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 164.5" - 225" Length | AGP150S1 RA3 | FSA stands for Floating Suction Adapter. | |
| | 0410141-091 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 76.9" - 107.4" Length | AGP150S1 RA1 FSA | | |
| | 0410141-092 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 106.9" - 167.4" Length | AGP150S1 RA2 FSA | | |
| | 0410141-093 | 4" TRJ RA STP - Quick Set (Adjustable) Final Assemblies, 166.9" - 227.4" Length | AGP150U1 RA3 FSA | | |
| | The Red Jacket RA Submersible Turbine Pump Model is UL Listed for: | | | STP Application Description | |
| Fuel Compatibility | 100% Gasoline 100% Diesel 80% Gasoline with 20% TAME, ETBE or MTBE Gasoline 85% Gasoline with 15% Methanol 90% Gasoline with 10% Ethanol | | | STP shall be of submersible centrifugal type which installs through a standard 4" threaded tank opening. Motor size shall be from 3/4 through 2 HP, depending upon required flow rates and head loss of a given piping system. | |
| | Pump | | | Impellers and Diffusers | |
| | lubricating and discharge pipir systems. The p | multi-stage, dependent upon required flow ra easily removed from storage tank without d Ig, mechanical or electronic leak detectors o sump and motor assembly shall be readily se nn pipe to allow for simple field replacement | Impellers shall be splined to the pump shaft to provide positive, non-slip rotation. Diffusers shall be tightly secured to prevent rotation. | | |
| | Pump Intake Inlet | | | Manifold Head Assembly | |
| Mechanical Features | Pump intake inlet shall be horizontal to prevent drawing sediment from the tank bottom into the pump inlet. The intake inlet shall be compatible with the particulate "Trapper" to prevent particulate from being ingested into the motor. | | | Manifold head assembly shall consist of a manifold and extractable packer assembly and shall be completely sealed against product leakage into the ground and exterior water intrusion into the storage tank. The discharge outlet shall be a 2" NPT opening. The manifold shall have a built-in air purge screw, line check valve, pressure relief valve, and shall support dual vacuum sensor siphon systems when required. The extractable packer shall incorporate industrial die springs to break loose the o-ring seals, when the flange nuts holding the extractable packer in place are removed. No physical lifting effort or special equipment shall be required to break the extractable packer seals. The contractor's box shall be built into the manifold head assembly and be completely isolated from the fuel path. The extractable packer assembly shall incorporate a lifting eye for safe extraction of the pump motor. | |



| | Electrical Disconnect | Check Valve with "Lock-n-Lift" Feature | |
|------------------------------------|---|---|--|
| Mechanical Features (Continued) | The electrical disconnect shall be an integral part of the manifold assembly. The electrical disconnect shall automatically disconnect and sever electrical connection to the pump motor, without a swing joint, when the extractable packer assembly is removed. Re-insertion of the extractable packer and tightening of the flange nuts shall remake the electrical connection. | The check valve shall incorporate a "Lock-n-Lift" feature that mechanically locks the check valve and lifts to provide a larger path to depressurize the line and manifold head assembly, returning fuel to the tank preventing service spills. The check valve shall provide pressure relief of the product line and be optimized for compatibility with Veeder-Root PLLD systems. | |
| | Vacuum Sensor Siphon System | Quick Set® | |
| | The vacuum sensor siphon system shall be capable of drawing 25" of mercury vacuum through a venturi. The vacuum sensor siphon shall incorporate a check valve to maintain the siphon system vacuum after the pump has been turned off. Check valves shall be incorporated on the siphon inlet and fuel source inlet to the venturi. The inlet shall incorporate a screen that reduces clogs and failures that can cause false alarms on vacuum monitor systems. The vacuum sensor siphon system shall incorporate a swivel top for easy connection to siphon tubing. The vacuum sensor siphon system shall be designed to integrate with Veeder-Root Vacuum Sensors. The manifold head assembly shall support dual vacuum sensor siphon systems for vacuum monitoring or siphon manifold applications. Unused vacuum siphon ports shall be sealed with a plug designed specifically for that purpose. | The Quick Set feature shall be capable of varying the overall pump length. The Quick Set shall incorporate a collet gripping mechanism and setscrew as a locking mechanism allowing future resizing. | |
| Electrical Features | Electric Motors – 4" Models | Connections | |
| | The motor shall be 208/230 volt, 60Hz, single-phase, 3450 RPM, permanent split capacitor type continuous duty, rated explosion proof in Class 1, Group D, petroleum products. The motor windings shall be hermetically sealed against leakage of product or moisture, and shall have a thermal overload device with automatic reset built into the motor windings for motor cut-off when motor temperature reaches a level which may cause damage to the motor. | The motor shall have a quick-disconnect type male/female connector to be readily separable for servicing without cutting or splicing of conducting wires. Wiring connections to the motor shall be disconnected by the quick- disconnect. Reconnecting motor to column pipe shall use an alignment dowel pin for positive realignment of electrical male/female connector. | |
| | Accessibility | Assembly Order | |
| Construction | | | |
| Construction | All components shall be designed and assembled to facilitate disassembly and servicing from above without disrupting the discharge piping, leak detection equipment and vacuum sensor siphon systems. | The pump shall be assembled with the pump inlet and impellers at the bottom for maximum liquid draw. The motor is to be mounted above the pump inlet, so that the motor is both cooled and lubricated by the liquid flow through and past the motor. | |
| Construction | disassembly and servicing from above without disrupting the discharge | inlet and impellers at the bottom for maximum liquid draw. The motor is to be mounted above the pump inlet, so that the motor is both cooled and lubricated by the liquid flow through and past the motor. hardware from The Red Jacket AG STP. hd 105°F (40.5°C) in non-gelling D°F (-4°C) and 125°F (51°C) ambient environment. | |
| | disassembly and servicing from above without disrupting the discharge piping, leak detection equipment and vacuum sensor siphon systems. The Red Jacket RA STP has an additional 30% increase in stainless steel The pump assembly shall be rated for operation between -40°F (-40°C) at petroleum products. The pump assembly shall be listed under UL 79 for operation between -2 The product temperature must not exceed 105°F (40.5°C). Petroleum shall not exceed the specific gravity as stated in the installation the specific pump model. | inlet and impellers at the bottom for maximum liquid draw. The motor is to be mounted above the pump inlet, so that the motor is both cooled and lubricated by the liquid flow through and past the motor. hardware from The Red Jacket AG STP. hd 105°F (40.5°C) in non-gelling D°F (-4°C) and 125°F (51°C) ambient environment. | |



| | 4" Red Jacket RA STP Models | | | | |
|--|-------------------------------|---|---|--|--|
| | Component | Material | Surface Finish | | |
| | Packer/Manifold Head | Gray Cast Iron | Powder Coat | | |
| | Elastomers – "O" Rings | High Grade Fluorocarbon | None | | |
| | Check Valve Seat | Stainless Steel | None | | |
| | Check Valve Lock Down Screw | Stainless Steel | None | | |
| | Column Pipes | Stainless Steel | None | | |
| Conduit Pipe | | 1/2" Steel Pipe | Mill Finish | | |
| | Quick Set Connector | Stainless Steel | Passivation | | |
| Bill of Materials | Discharge Head | Gray Cast Iron | Powder Coat | | |
| Bill of Materials | Retaining Nuts | Stainless Steel | Passivation | | |
| | Die Springs | Stainless Steel | Passivation | | |
| | Purge Screw | Stainless Steel | Passivation | | |
| | Siphon Cartridge | Stainless Steel | Passivation | | |
| | | Pump/Motor | | | |
| | Outer Shell | Stainless Steel | None | | |
| | Stator Shell | Stainless Steel | None | | |
| | Rotor Shaft | Stainless Steel | None | | |
| | Impellers & Diffusers | (Acetel) Celcon® Plastic | None | | |
| | Motor Bearings | Carbon | None | | |
| The F | Red Jacket RA STP Performance | The Red Jack | et RA STP Dimensions | | |
| AGP150S1 100 40 40 50 40 40 10 100 100 100 100 100 | erformance @ 230V; SG = 0.78 | Forecourt Mar Packer Manifold Clearance 4" Minimum Image: Clearance 4" Miser 11.7" (297 mm) Riser 4" Riser Pipe Diameter Column Pipe Length Image: Clearance Pipe Diameter Column Pipe Length Unitized Motor Pump (UMP) Image: Clearance Column Pipe Length Image: Clearance Pipe Diameter Image: Clearance | hhole - Packer 2" Discharge Manifold 0 Dispensers Containment Bury Depth Tank Manway Tank Diameter And trapper | | |

veeder.com +1.800.873.3313 125 Powder Forest Drive • PO Box 2003 • Simsbury, CT 06070 • ©2022 Veeder-Root • P/N 577014-468-12 Rev. A All information contained in this document is subject to change without notice. Veeder-Root makes no warranty of any kind with regard to this publication, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose.

Veeder-Root shall not be liable for errors contained herein or for incidental or consequential damages in connection with the furnishing, performance, or use of this publication.

Veeder-Root reserves the right to change system options or features, or the information contained in this publication.

This publication contains proprietary information which is protected by copyright. All rights reserved. No part of this publication may be photocopied, reproduced, or translated to another language without the prior written consent of Veeder-Root.

Example Illustrations

Illustrations used in this guide may contain components that are customer supplied and not included with the Red Jacket Submersible Turbine Pump. Please check with your Veeder-Root Distributor for recommended installation accessories.